



PROCESS CONTROL INSTRUMENTS LABORATORY

ULR No. CC228719200000524F

Page 2 of 2

Date of Calibration : 2 to 3 / 04 / 2019


Certificate No. CC / TRL / 0816 / 18-19


CALIBRATION RESULTS

| Standard Reading in °C | UUC Reading in °C | Position Of Pointer on Dia Knob of Heat Detector |
|---------------------------|----------------------|---|
| 76.175 | 76 | 0.1 |
| 80.171 | 80 | 1.0 |
| 89.974 | 90 | 1.5 |
| 95.214 | 95 | 1.8 |
| 120.191 | 120 | 2.9 |
| 140.213 | 140 | 3.9 |

Remark:

- (1) The readings of Temperature represent the mean of five readings.
- (2) Probe Type Heat Detector was tested at various temperatures as above with setting in Deg.C. During this test, Probe Type Heat Detector performed satisfactory at each and every temp. set point by setting itself triggered & simillarly got automatically restored.


Calibrated By -


Checked By -

**** END OF RESULT ****